



Arizona Sizing Chart

Infiltrator® Quick4® High Capacity (Q4HC) and Quick4® Plus™ High Capacity (Q4+HC) Chambers

Percolation Rate (min/in)	Application Rate (gal/day/sq ft)	1 Bedroom 150 gal/day		2 Bedrooms 300 gal/day		3 Bedrooms 450 gal/day		4 Bedrooms 600 gal/day	
		Square Feet Required	Number of Chambers Required	Square Feet Required	Number of Chambers Required	Square Feet Required	Number of Chambers Required	Square Feet Required	Number of Chambers Required
< 1	Not Permitted	---	---	---	---	---	---	---	---
> 1, ≤ 3	1.20	125	15	250	15	375	15	500	18
3	1.10	136	15	273	15	409	15	545	20
4	1.00	150	15	300	15	450	15	600	22
5	0.90	167	15	333	15	500	18	667	24
7	0.75	200	15	400	15	600	22	800	29
10	0.63	238	15	476	17	714	26	952	34
15	0.50	300	15	600	22	900	32	1,200	43
20	0.44	341	15	682	25	1,023	37	1,364	49
25	0.40	375	15	750	27	1,125	40	1,500	53
30	0.36	417	15	833	30	1,250	45	1,667	59
35	0.33	455	17	909	33	1,364	49	1,818	65
40	0.31	484	18	968	35	1,452	52	1,935	69
45	0.29	517	19	1,034	37	1,552	55	2,069	73
50	0.28	536	19	1,071	38	1,607	57	2,143	76
55	0.27	556	20	1,111	40	1,667	59	2,222	79
> 55, ≤ 60	0.25	600	22	1,200	43	1,800	64	2,400	85
> 60, ≤ 120	0.20	750	27	1,500	53	2,250	80	3,000	106

The Quick4 High Capacity (Q4HC) and Quick4 Plus High Capacity (Q4+HC) chambers are credited with 28.4 square feet of absorption area per chamber per A.A.C. R18-9-E302(C)(4).
The minimum recommended number of chambers per system is 15.